




# Construction Management

University of Missouri-Columbia

## Planning, Design & Construction Campus Facilities

117 General Services Building  
Columbia, MO 65211-3200



PROJECT:

Date:

PHONE (573) 882-1133

FAX (573) 882-1175

### INSPECTION REPORT

### DIGITAL CONTROL EQUIPMENT PNEUMATIC TUBING PRESSURE TEST

TEST	LINES TESTED	PASS/FAIL
24 Hr Pressure Test @ 30 PSI		
MUST NOT LOSE MORE THAN 5 PSI TO PASS		

Subcontractor \_\_\_\_\_ General Contractor \_\_\_\_\_

MU Representative \_\_\_\_\_

MU initials to verify items on checklist only. Contractor responsible for compliance with plans and specifications.

**\*Fill out all form fields before signing!**

Name	Organization	Title	Signature
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

University of Missouri Commissioning Authority



(Place Digital Locking Stamp Here)

Cc: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

REPORT 15975.3